



Government of West Bengal
Office of the Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata – 16

Memo No.:FSR/WBFES/4663/17/Cal/B/58/2002/2(373)

Date : 03-06-2025

From :
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To :
Bharatiya Vidya Bhavan
FA-III, SECTOR-III, SALT LAKE, KOLKATA-700097

Sub : Fire Safety Certificate for Existing Construction of Ground + 9 Storied Building of 'BLOCK VIII' under Principal Group Occupancy "Educational" Building in the name & style of "Bharatiya Vidya Bhavan", at Premises No- FA-III, Sector-III, Salt Lake, P. S -Bidhan Nagar (E), Dist- North 24 Parganas, Kolkata – 700097, W. B, India.

This is in reference to your AIN 211892506300006350 dated 20-Apr-2025 regarding Fire Safety Certificate for Existing Construction of Ground + 9 Storied Building of 'BLOCK VIII' under Principal Group Occupancy "Educational" Building in the name & style of "Bharatiya Vidya Bhavan", at Premises No- FA-III, Sector-III, Salt Lake, P. S -Bidhan Nagar (E), Dist- North 24 Parganas, Kolkata – 700097, W. B, India..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

FSC with condition to pressurize lift & stairs as per FSR/approved plan drawing by 16th June, 2025.

1. The Management of the Bharatiya Vidya Bhavan shall maintain all the fire prevention, fire safety and fire protection measures in good repair and efficient condition at all the time in accordance with



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300006350

Section 11 C of West Bengal Fire Service Act 1950 with up-to date amendment.

2. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.

No parking will be allowed on the Drive way. Necessary clearance to be maintained on the ground level below Fire Refuge Areas of the building for placing & operation of High Rise Ladder.

3. The Interior finish decoration of the School building shall be made with low flame spread material confirming to the I. S. Specification.

4. The Building shall not be used for the storage of any hazardous materials i.e., Volatile flammable liquids. If stored then, it shall be restricted to science laboratories only.

5. Rooms used by the preschool, Grade-1 students shall be located on ground floor of exit discharge. Room occupied by class II students shall be located not above one floor higher than ground floor of exit discharge.

6. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outsides of the building shall be strictly maintained.

7. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.

8. A fire control room including a closed circuit T.V. system will have to maintain to monitor entire the building.

9. The notice of Fire Fighting and Evacuation from the building shall be displayed at all proper places of the building.

10. The employees and security staff shall be conversant with installed fixed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.

11. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building- ANNEX D (Clause 4.11) of NBC-2016.

12. Switch Gear, Transformer, Generator room, Electrical Panel Rooms shall have to be protected by suitable automatic fire suppression system such as Modular Fire Extinguishers or CO-2 or DCP Fire Extinguisher conforming I. S. Specification.

13. A crew of trained Fireman under a qualified and experience officer shall be maintained round the clock for safety of the building.

14. The Fire Check Door shall be sealed with rubber sealing properly and automatic door closer of each FCD shall be maintained all the time in order to prevent the percolation of smoke.

15. Periodical flashing of water in the Hydrants and Wet-Riser pipe line shall be made to maintain the efficiency working performance of above mention system.

16. First-Aid-Fire Fighting system shall be provided as per I. S. Specification.

17. Periodical check-up of manually Electrical Fire Alarm system with break glass type call boxes fitted with flusher cum hooters, Auto detectors, auto sprinkler system, vertical ducts sealing by fire resisting material etc. at each floor connecting with control panel to be conducted.

18. Emergency Battery Backup for suitable lighting arrangements shall be maintained for safe evacuation in case of any emergency.

19. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.

20. Electrical Audit shall be conducted by Government approved licence holder engineer and certificate must be submitted in the office at the time of renewal of Fire Safety Certificate.

21. The Fire Safety Certificate is valid for three years and has to be renewed after every three years from the date of issue of this letter.

Valid Upto : 01-Jun-2028



Signature valid

Digitally Signed.
Name: ABHINAV PANDAY
Date: 03-Jun-2025 15:58:28
Reason: D-Sign
Location: E-Dist 2.0

Director

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300006350