



# SUPERINTENDENCE COMPANY OF INDIA PRIVATE LIMITED

LABORATORY :


PLOT NO. Y-23, BLOCK-EP, SECTOR-V, SALT LAKE CITY, KOLKATA-700 091

☎ : (033) 2357-4671 / 4681 / 5039 / 5042 • Fax : (033) 2357- 4806

E mail : supind2019@gmail.com / supind50@yahoo.co.in

Website : www.superintendencecoindia.com

GSTIN : 19AAECS3740C2ZJ



(In ISO 9001 : 2015 Certified)

Form No.: SUP/IT/7.8/F1

Issue date: 06.02.2019

Amend - I dt. 02.05.2019



TC-8066

## TEST REPORT

Page 1 of 2

Name & Address of Customer : BHARATIYA VIDYA BHAVAN  
Block - FA, Sector - III, Salt Lake City, Kolkata - 700 097

Letter Ref. No. & Date : BVB/KOL/WO/2025-26/56 Ddate: 05.08.2025

Job No. with Date : N-1255 Date: 05.08.2025

Sample Received Date : 05.08.2025

Test performed on : 05.08.2025 to 13.08.2025

Material : Drinking water (Main Building DW2)

Work of Testing of Drinking Water (5nos. Tank) at Secondary Section, Primary Section, New Building and Bhavan's Institute of Management Science of Bharatiya Vidya Bhavan, Salt Lake, Kolkata

ULR-TC806625000001870F

Test Report No: N-1256

Dated: 14.08.2025

### I. Chemical Testing

#### 1. Water

#### Drinking Water As per IS:10500/2012

S.N	Specific Test Performed	Limit		Test Method Specification against which tests are performed	Test Results
		Acceptable	Premissible		
1	pH at 25°C	6.5 to 8.5	No relaxation	IS:3025 P-II	6.99
2	Colour (Hazen Units) max	5	15	APHA, 24th edition 2120 B	<1.0
3	Turbidity (NTU) max	1	5	IS:3025 (P-10)	<1.0
4	Residual Free Chlorine (mg/l)	0.2	1	IS:3025 (P-26)	<0.2
5	Alkalinity as CaCO <sub>3</sub> (mg/l)	200	600	IS:3025 (P-23)	19.0
6	Total Hardness as CaCO <sub>3</sub> (mg/l)	200	600	APHA, 24th Edition, 2340C	15.0
7	Chloride as Cl (mg/l)	250	1000	IS:3025 (P-32)	8.0
8	Calcium as Ca (mg/l)	75	200	APHA, 24th edition, 3500 Ca-B	4.4
9	Magnesium as Mg (mg/l)	30	100	APHA, 24th edition, 3500 Mg-B	0.97
10	Iron as Fe (mg/l)	0.3	No relaxation	APHA, 24th edition, 3111B	<0.05
11	Sulphate as SO <sub>4</sub> (mg/l)	200	400	APHA, 24th edition 4500 E	0.92
12	Nitrate as NO <sub>3</sub> (mg/l)	45	No relaxation	APHA, 24th edition, 4500 NO <sub>3</sub> B	0.246

Continued in Page.....2

Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.  
2) This Report shall not be reproduced in part or full without written permission of the management.  
3) Liability for return of samples ceases after 15 days from the date of test report.





# SUPERINTENDENCE COMPANY OF INDIA PRIVATE LIMITED

LABORATORY :

PLOT NO. Y-23, BLOCK-EP, SECTOR-V, SALT LAKE CITY, KOLKATA-700 091

☎ : (033) 2357-4671/ 4681 / 5039 / 5042 • Fax : (033) 2357- 4806

E-mail : supind2019@gmail.com / supind50@yahoo.co.in

Website : www.superintendencecoindia.com



(An ISO 9001 : 2015 Certified)

Form No.: SUP/T/7.8/F1

Issue date: 06.02.2019

Amend - I dt. 02.05.2019



TC-8066

GSTIN : 19AAECS3740C2ZJ

## TEST REPORT

Page 2 of 2

ULR-TC806625000001870F

Test Report No: N-1256

Dated: 14.08.2025

### I. Chemical Testing

#### I. Water

S.N	Specific Test Performed	Requirement		Test Method Specification against which tests are performed	Test Results
		Acceptable Limit	Premissible Limit		
13	Copper as Cu (mg/l)	0.05	1.5	APHA, 24th edition, 3111 B	<0.05
14	Manganese as Mn (mg/l)	0.1	0.3	APHA, 24th edition, 3111.B	<0.05
15	Zinc as Zn (mg/l)	5	15	APHA, 24th edition, 3111 B	<0.05
16	Cadmium as Cd (mg/l)	0.003	No relaxation	APHA, 24th edition, 3111 B (AAS)	<0.003
17	Total Chromium as Cr (mg/l) max	0.05	No relaxation	APHA, 24th edition, 3500 B	<0.05
18	Aluminium as Al (mg/l) max	0.03	0.2	APHA, 24th edition, 3500 Al.B	<0.05
19	Boron as B (mg/l)	0.5	1	APHA, 24th edition, 4500B-B	<1.0
20	Mercury as Hg (mg/l)	0.001	No relaxation	IS: 3025(P-48) Mercury analyser	<0.001
21	Cyanide as CN (mg/l)	0.05	No relaxation	APHA, 24th edition, 4500 E	<0.05
22	Phenolic Compounds as C <sub>6</sub> H <sub>5</sub> OH(mg/l)	0.001	0.002	APHA, 24th edition, 5530 D	<0.002
23	Total Dissolved solids (mg/l)	500	2000	IS:3025(P-16)	29.0
24	Fluoride as F (mg/l)	1	1.5	APHA, 24th edition, 4500 F-D	0.13
25	Arsenic as As (mg/l)	0.01	0.05	APHA 24th edition, 3120-B	<0.05
26	Lead as Pb (mg/l)	0.01	No relaxation	APHA 24th edition, 3120-B	<0.01

Tested By:

*P. Bhattacharya*

P. Bhattacharya,

Reviewed & Approved By:

*D. Roy*

D. Roy

Authorised Signatory

*P. Dutta*

P. Dutta

(Technical Manager)

END OF THE REPORT

- Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.  
2) This Report shall not be reproduced in part or full without written permission of the management.  
3) Liability for return of samples ceases after 15 days from the date of test report.



# SUPERINTENDENCE COMPANY OF INDIA PRIVATE LIMITED, TESTING LABORATORIES

## LABORATORY :

PLOT NO. Y-23, BLOCK-EP, SECTOR-V, SALT LAKE CITY, KOLKATA-700 091

☎ : (033) 2357-4671 / 4681 / 5039 / 5042 • Fax : (033) 2357- 5039

E-mail : supind2019@gmail.com / supind50@yahoo.co.in

Website : www.superintendencecoindia.com



(An ISO 9001 : 2015 Certified)

GSTIN : 19AAECS3740C2ZJ

MSME NO UDYAM-WB-140001361

CIN NO U74140WB1955PTC022400

## TEST REPORT

Name & Address of Customer : BHARATIYA VIDYA BHAVAN  
Block - FA, Sector - III, Salt Lake City, Kolkata - 700 097

Letter Ref. No. & Date : BVB/KOL/WO/2025-26/56 Date: 05.08.2025

Job No. with Date : N-1255 Date: 05.08.2025

Sample Received Date : 05.08.2025

Test performed on : 05.08.2025 to 13.08.2025

Material : Drinking water (Main Building DW2)  
Work of Testing of Drinking Water (5nos. Tank) at Secondary Section, Primary Section, New Building and Bhavan's Institute of Management Science of Bharatiya Vidya Bhavan, Salt Lake, Kolkata

Test Report No: N-1256

Dated: 14.08.2025

### Drinking Water As per IS:10500/2012

S.N	Specific Test Performed	Limit		Test Method Specification against which tests are performed	Test Results
		Acceptable	Permissible		
1	Odour	Agreeable	Agreeable	IS: 3025 (P-5)	Agreeable
2	Taste	Agreeable	Agreeable	IS:3025 (P-7 & 8)	Agreeable
3	Mineral Oil (mg/l)	0.5	No relaxation	IS: 3025 (P-39)	<0.5
4	Selenium as Se (mg/l)	0.01	No relaxation	IS: 3025 (P-56)	<0.01

Tested By:

*P. Bhattacharya*

P. Bhattacharya,

Reviewed & Approved By:

*D. Roy*

D. Roy

Authorised Signatory

*P. Dutta*

P. Dutta

(Technical Manager)

END OF THE REPORT

Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.  
2) This Report shall not be reproduced in part or full without written permission of the management.  
3) Liability for return of samples ceases after 15 days from the date of test report.





# SUPERINTENDENCE COMPANY OF INDIA PRIVATE LIMITED

LABORATORY :


PLOT NO. Y-23, BLOCK-EP, SECTOR-V, SALT LAKE CITY, KOLKATA-700 091

☎ : (033) 2357-4671 / 4681 / 5039 / 5042 • Fax : (033) 2357- 4806

E-mail : supind2019@gmail.com / supind50@yahoo.co.in

Website : www.superintendencecoindia.com

GSTIN : 19AAECS3740C2ZJ



(An ISO 9001 : 2015 Certified)

Form No.: SUP/T/7.8/F1

Issue date: 06.02.2019

Amend - I dt. 02.05.2019



TC-8066

## TEST REPORT

Page 1 of 2

Name & Address of Customer : BHARATIYA VIDYA BHAVAN  
Block - FA, Sector - III, Salt Lake City, Kolkata - 700 097

Letter Ref. No. & Date : BVB/KOL/WO/2025-26/56 Date: 05.08.2025

Job No. with Date : N-1255 Date: 05.08.2025

Sample Received Date : 05.08.2025

Test performed on : 05.08.2025 to 13.08.2025

Material : Drinking water (New Building DW3)  
Work of Testing of Drinking Water (5nos. Tank) at Secondary Section, Primary Section, New Building and Bhavan's Institute of Management Science of Bharatiya Vidya Bhavan, Salt Lake, Kolkata

ULR-TC806625000001871F

Test Report No: N-1257

Dated: 14.08.2025

### I. Chemical Testing

#### 1. Water

Drinking Water As per IS:10500/2012

S.N	Specific Test Performed	Limit		Test Method Specification against which tests are performed	Test Results
		Acceptable	Premissible		
1	pH at 25°C	6.5 to 8.5	No relaxation	IS:3025 P-II	7.85
2	Colour (Hazen Units) max	5	15	APHA, 24th edition 2120 B	<1.0
3	Turbidity (NTU) max	1	5	IS:3025 (P-10)	<1.0
4	Residual Free Chlorine (mg/l)	0.2	1	IS:3025 (P-26)	<0.2
5	Alkalinity as CaCO <sub>3</sub> (mg/l)	200	600	IS:3025 (P-23)	75.0
6	Total Hardness as CaCO <sub>3</sub> (mg/l)	200	600	APHA, 24th Edition, 2340C	78.0
7	Chloride as Cl (mg/l)	250	1000	IS:3025 (P-32)	15.0
8	Calcium as Ca (mg/l)	75	200	APHA, 24th edition, 3500 Ca-B	27.2
9	Magnesium as Mg (mg/l)	30	100	APHA, 24th edition, 3500 Mg-B	2.43
10	Iron as Fe (mg/l)	0.3	No relaxation	APHA, 24th edition, 3111B	<0.05
11	Sulphate as SO <sub>4</sub> (mg/l)	200	400	APHA, 24th edition 4500 E	8.5
12	Nitrate as NO <sub>3</sub> (mg/l)	45	No relaxation	APHA, 24th edition, 4500 NO <sub>3</sub> B	0.208

Continued in Page.....2

Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.  
2) This Report shall not be reproduced in part or full without written permission of the management.  
3) Liability for return of samples ceases after 15 days from the date of test report.





# SUPERINTENDENCE COMPANY OF INDIA PRIVATE LIMITED

LABORATORY :

PLOT NO. Y-23, BLOCK-EP, SECTOR-V, SALT LAKE CITY, KOLKATA-700 091

☎ : (033) 2357-4671/ 4681 / 5039 / 5042 • Fax : (033) 2357- 4806

E-mail : supind2019@gmail.com / supind50@yahoo.co.in

Website : www.superintendencecoindia.com



(An ISO 9001 : 2015 Certified)

Form No.: SUP/T/7.8/F1

Issue date: 06.02.2019

Amend - I dt. 02.05.2019



TC-8066

GSTIN : 19AAECS3740C2ZJ

## TEST REPORT

Page 2 of 2

ULR-TC806625000001871F

Test Report No: N-1257

Dated: 14.08.2025

### I. Chemical Testing

#### I. Water

S.N	Specific Test Performed	Requirement		Test Method Specification against which tests are performed	Test Results
		Acceptable Limit	Permissible Limit		
13	Copper as Cu (mg/l)	0.05	1.5	APHA, 24th edition, 3111 B	<0.05
14	Manganese as Mn (mg/l)	0.1	0.3	APHA, 24th edition, 3111.B	<0.05
15	Zinc as Zn (mg/l)	5	15	APHA, 24th edition, 3111 B	<0.05
16	Cadmium as Cd (mg/l)	0.003	No relaxation	APHA, 24th edition, 3111 B (AAS)	<0.003
17	Total Chromium as Cr (mg/l) max	0.05	No relaxation	APHA, 24th edition, 3500 B	<0.05
18	Aluminium as Al (mg/l) max	0.03	0.2	APHA, 24th edition, 3500 Al.B	<0.05
19	Boron as B (mg/l)	0.5	1	APHA, 24th edition, 4500B-B	<1.0
20	Mercury as Hg (mg/l)	0.001	No relaxation	IS: 3025(P-48) Mercury analyser	<0.001
21	Cyanide as CN (mg/l)	0.05	No relaxation	APHA, 24th edition, 4500 E	<0.05
22	Phenolic Compounds as C <sub>6</sub> H <sub>5</sub> OH(mg/l)	0.001	0.002	APHA, 24th edition, 5530 D	<0.002
23	Total Dissolved solids (mg/l)	500	2000	IS:3025(P-16)	126.0
24	Fluoride as F (mg/l)	1	1.5	APHA, 24th edition, 4500 F-D	0.06
25	Arsenic as As (mg/l)	0.01	0.05	APHA 24th edition, 3120-B	<0.05
26	Lead as Pb (mg/l)	0.01	No relaxation	APHA 24th edition, 3120-B	<0.01

Tested By:

P. Bhattacharya

P. Bhattacharya,

Reviewed & Approved By:

D. Roy

D. Roy

Authorised Signatory

P. Dutta

(Technical Manager)

END OF THE REPORT

- Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.  
2) This Report shall not be reproduced in part or full without written permission of the management.  
3) Liability for return of samples ceases after 15 days from the date of test report.



# SUPERINTENDENCE COMPANY OF INDIA PRIVATE LIMITED, TESTING LABORATORIES

## LABORATORY :

PLOT NO. Y-23, BLOCK-EP, SECTOR-V, SALT LAKE CITY, KOLKATA-700 091  
☎ : (033) 2357-4671 / 4681 / 5039 / 5042 • Fax : (033) 2357- 5039  
E-mail : supind2019@gmail.com / supind50@yahoo.co.in  
Website : www.superintendencecoindia.com



(An ISO 9001 : 2015 Certified)

GSTIN : 19AAECS3740C2ZJ

MSME NO UDYAM-WB-140001361

CIN NO U74140WB1955PTC022400

## TEST REPORT

Name & Address of Customer : BHARATIYA VIDYA BHAVAN  
Block - FA, Sector - III, Salt Lake City, Kolkata - 700 097

Letter Ref. No. & Date : BVB/KOL/WO/2025-26/56 Ddate: 05.08.2025  
Job No. with Date : N-1255 Date: 05.08.2025  
Sample Received Date : 05.08.2025  
Test performed on : 05.08.2025 to 13.08.2025  
Material : Drinking water (New Building DW3)  
Work of Testing of Drinking Water (5nos. Tank) at Secondary Section, Primary Section, New Building and Bhavan's Institute of Management Science of Bharatiya Vidya Bhavan, Salt Lake, Kolkata

Test Report No: N-1257

Dated: 14.08.2025

### Drinking Water As per IS:10500/2012

S.N	Specific Test Performed	Limit		Test Method Specification against which tests are performed	Test Results
		Acceptable	Permissible		
1	Odour	Agreeable	Agreeable	IS: 3025 (P-5)	Agreeable
2	Taste	Agreeable	Agreeable	IS:3025 (P-7 & 8)	Agreeable
3	Mineral Oil (mg/l)	0.5	No relaxation	IS: 3025 (P-39)	<0.5
4	Selenium as Se (mg/l)	0.01	No relaxation	IS: 3025 (P-56)	<0.01

Tested By:

*P. Bhattacharya*

P. Bhattacharya,

Reviewed & Approved By:

*D. Roy*

D. Roy

Authorised Signatory

*P. Dutta*

P. Dutta

(Technical Manager)

END OF THE REPORT

Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.  
2) This Report shall not be reproduced in part or full without written permission of the management.  
3) Liability for return of samples ceases after 15 days from the date of test report.





TC-8066

GSTIN : 19AAECS3740C2ZJ

## TEST REPORT

Page 1 of 2

**Name & Address of Customer :** BHARATIYA VIDYA BHAVAN  
Block - FA, Sector - III, Salt Lake City, Kolkata - 700 097

**Letter Ref. No. & Date :** BVB/KOL/WO/2025-26/56 **Date:** 05.08.2025

**Job No. with Date :** N-1255 **Date:** 05.08.2025

**Sample Received Date :** 05.08.2025

**Test performed on :** 05.08.2025 to 13.08.2025

**Material :** Drinking water (Primary Building DW4)  
Work of Testing of Drinking Water (5nos. Tank) at Secondary Section, Primary Section, New Building and Bhavan's Institute of Management Science of Bharatiya Vidya Bhavan, Salt Lake, Kolkata

ULR-TC806625000001872F

Test Report No: N-1258

Dated: 14.08.2025

### I. Chemical Testing

#### 1. Water

#### Drinking Water As per IS:10500/2012

S.N	Specific Test Performed	Limit		Test Method Specification against which tests are performed	Test Results
		Acceptable	Premissible		
1	pH at 25°C	6.5 to 8.5	No relaxation	IS:3025 P-II	7.60
2	Colour (Hazen Units) max	5	15	APHA, 24th edition 2120 B	<1.0
3	Turbidity (NTU) max	1	5	IS:3025 (P-10)	<1.0
4	Residual Free Chlorine (mg/l)	0.2	1	IS:3025 (P-26)	<0.2
5	Alkalinity as CaCO <sub>3</sub> (mg/l)	200	600	IS:3025 (P-23)	35.0
6	Total Hardness as CaCO <sub>3</sub> (mg/l)	200	600	APHA, 24th Edition, 2340C	37.0
7	Chloride as Cl (mg/l)	250	1000	IS:3025 (P-32)	11.0
8	Calcium as Ca (mg/l)	75	200	APHA, 24th edition, 3500 Ca-B	12.0
9	Magnesium as Mg (mg/l)	30	100	APHA, 24th edition, 3500 Mg-B	1.70
10	Iron as Fe (mg/l)	0.3	No relaxation	APHA, 24th edition, 3111B	<0.05
11	Sulphate as SO <sub>4</sub> (mg/l)	200	400	APHA, 24th edition 4500 E	2.2
12	Nitrate as NO <sub>3</sub> (mg/l)	45	No relaxation	APHA, 24th edition, 4500 NO <sub>3</sub> B	NT

Continued in Page.....2

Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.  
2) This Report shall not be reproduced in part or full without written permission of the management.  
3) Liability for return of samples ceases after 15 days from the date of test report.





TC-8066

GSTIN : 19AAECS3740C2ZJ

## TEST REPORT

Page 2 of 2

ULR-TC806625000001872F

Test Report No: N-1258

Dated: 14.08.2025

### I. Chemical Testing

#### 1. Water

S.N	Specific Test Performed	Requirement		Test Method Specification against which tests are performed	Test Results
		Acceptable Limit	Permissible Limit		
13	Copper as Cu (mg/l)	0.05	1.5	APHA, 24th edition, 3111 B	<0.05
14	Manganese as Mn (mg/l)	0.1	0.3	APHA, 24th edition, 3111.B	<0.05
15	Zinc as Zn (mg/l)	5	15	APHA, 24th edition, 3111 B	<0.05
16	Cadmium as Cd (mg/l)	0.003	No relaxation	APHA, 24th edition, 3111 B (AAS)	<0.05
17	Total Chromium as Cr (mg/l) max	0.05	No relaxation	APHA, 24th edition, 3500 B	<0.05
18	Aluminium as Al (mg/l) max	0.03	0.2	APHA, 24th edition, 3500 Al.B	<0.05
19	Boron as B (mg/l)	0.5	1	APHA, 24th edition, 4500B-B	<1.0
20	Mercury as Hg (mg/l)	0.001	No relaxation	IS: 3025(P-48) Mercury analyser	<0.001
21	Cyanide as CN (mg/l)	0.05	No relaxation	APHA, 24th edition, 4500 E	<0.05
22	Phenolic Compounds as C <sub>6</sub> H <sub>5</sub> OH(mg/l)	0.001	0.002	APHA, 24th edition, 5530 D	<0.002
23	Total Dissolved solids (mg/l)	500	2000	IS:3025(P-16)	54.0
24	Fluoride as F (mg/l)	1	1.5	APHA, 24th edition, 4500 F-D	<0.05
25	Arsenic as As (mg/l)	0.01	0.05	APHA 24th edition, 3120-B	<0.05
26	Lead as Pb (mg/l)	0.01	No relaxation	APHA 24th edition, 3120-B	<0.01

Tested By:

*P. Bhattacharya*  
P. Bhattacharya,

Reviewed & Approved By:

*D. Roy*  
D. Roy

Authorised Signatory

*P. Dutta*  
P. Dutta  
(Technical Manager)

END OF THE REPORT

Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.  
 2) This Report shall not be reproduced in part or full without written permission of the management.  
 3) Liability for return of samples ceases after 15 days from the date of test report.





# SUPERINTENDENCE COMPANY OF INDIA PRIVATE LIMITED, TESTING LABORATORIES

LABORATORY :

PLOT NO. Y-23, BLOCK-EP, SECTOR-V, SALT LAKE CITY, KOLKATA-700 091  
☎ : (033) 2357-4671/ 4681 / 5039 / 5042 • Fax : (033) 2357- 5039  
E-mail : supind2019@gmail.com / supind50@yahoo.co.in  
Website : www.superintendencecoindia.com



(An ISO 9001 : 2015 Certified)

GSTIN : 19AAECS3740C2ZJ

MSME NO UDYAM-WB-140001361

CIN NO U74140WB1955PTC022400

## TEST REPORT

Name & Address of Customer : **BHARATIYA VIDYA BHAVAN**  
Block - FA, Sector - III, Salt Lake City, Kolkata - 700 097

Letter Ref. No. & Date : BVB/KOL/VO/2025-26/56 Date: 05.08.2025  
Job No. with Date : N-1255 Date: 05.08.2025  
Sample Received Date : 05.08.2025  
Test performed on : 05.08.2025 to 13.08.2025  
Material : Drinking water (Primary Building DW4)  
Work of Testing of Drinking Water (Snos. Tank) at Secondary Section, Primary Section, New Building and Bhavan's Institute of Management Science of Bharatiya Vidya Bhavan, Salt Lake, Kolkata

Test Report No: N-1258

Dated: 14.08.2025

### Drinking Water As per IS:10500/2012

S.N	Specific Test Performed	Limit		Test Method Specification against which tests are performed	Test Results
		Acceptable	Permissible		
1	Odour	Agreeable	Agreeable	IS: 3025 (P-5)	Agreeable
2	Taste	Agreeable	Agreeable	IS:3025 (P-7 & 8)	Agreeable
3	Mineral Oil (mg/l)	0.5	No relaxation	IS: 3025 (P-39)	<0.5
4	Selenium as Se (mg/l)	0.01	No relaxation	IS: 3025 (P-56)	<0.01

Tested By:

*P. Bhattacharya*  
P. Bhattacharya,

Reviewed & Approved By:

*D. Roy*  
D. Roy

Authorised Signatory

*P. Dutta*  
P. Dutta  
(Technical Manager)

END OF THE REPORT

Note : 1) This report refers to the values obtained at the time of testing and results relate to the items tested.  
2) This Report shall not be reproduced in part or full without written permission of the management.  
3) Liability for return of samples ceases after 15 days from the date of test report.